











Building Energy Performance		Scotland
Energy Performance Certificate	Calculated asset rating using IES <VE> 5.9.0.2 [ApacheSim]	Building type Further education universities
	Current rating	
	Excellent	
		Carbon Neutral
		A (0 to 15)
		B (16 to 30)
		C (31 to 45)
	D (46 to 60)	
	E (61 to 80)	
	F (81 to 100)	
	G (100+)	
Very Poor		
Carbon Dioxide Emissions		
The number refers to the calculated carbon dioxide emissions in terms of kg per m ² of floor area per year		14
Approximate current energy use per m ² of floor area:		82 kWh/m²
Main heating fuel: Biomass		Building Services: Heating with Nat. Vent.
Renewable energy source:		Electricity: Grid supplied
Carbon Dioxide is a greenhouse gas which contributes to climate change. Less Carbon Dioxide emissions from buildings helps the environment.		
Benchmarks		
A building of this type built to building regulations standards current at the date of issue of this certificate would have a rating:		23  B
Where the accompanying recommendations for the cost effective improvement of energy performance are applied, this building would have a rating:		0  Carbon Neutral
Recommendations for the cost-effective improvement (lower cost measures) of the energy performance		

Address: 2 Haghill Road, Glasgow, G31 3SR
 Conditioned area (m²): 6179.097
 Name of protocol organisation: CIBSE Certification Ltd
 Date of issue of certificate: 07 Jan 2009 (Valid for a period not exceeding 10 years)

This certificate is a requirement of EU Directive 2002/91/EC on the energy performance of buildings.

NB THIS CERTIFICATE MUST BE AFFIXED TO THE BUILDING AND NOT REMOVED UNLESS REPLACED WITH AN UPDATED VERSION AND FOR PUBLIC BUILDINGS DISPLAYED IN A PROMINENT PLACE